

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. [REDACTED]

Water Right Permit No.

29.3E.15K

(1) OWNER: Name R. GABELEIN Address 5785 S BAYVIEW RD. LANGLEY

(2) LOCATION OF WELL: County ISLAND NW 4 SE 4 Sec 15 T. 29 N., R. 3E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) MIDVALE RD. LANGLEY WA

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 93 feet. Depth of completed well 93 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 88 ft.
Welded ☒ " Diam. from _____ ft. to _____ ft.
Liner installed ☐ " Diam. from _____ ft. to _____ ft.
Threaded ☐ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Johnson
Type STAINLESS Model No. 3-4
Diam. 6 Slot size 10 from 88 ft. to 93 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 10+ ft.
Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
DIRTY SAND	0	38
SANDY CLAY	38	45
DIRTY SAND	45	75
CLAY	75	85
SOOPY SAND	85	89
WATER IN SAND	89	93
CLAY	93	

RECEIVED

FEB 27 1992

DEPT. OF ECOLOGY

Work started FEB 1992 Completed FEB 1992

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY WELL DRILL
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address OAK HARBOR WA

(Signed) Rennin John License No. 129
(WELL DRILLER)

Contractor's
Registration No. WHD209 NM Date FEB 1992

(USE ADDITIONAL SHEETS IF NECESSARY)